

DAILY IRRIGATION OUTAGE REPORT


System is
Running


System is
Not Running


Temporarily
Paused


Program
Changed

Outage Date	Controllor	Zone	Zone Type	Association /Area	Effected Addresses	Issue	Status	Service Restore Date
6/1/2020	68/70	39-41 80-83	Sprays/ Rotors	Kensington	1005-100, 1013-1015, 1014-1016 Chelsea Greens and 2494-2495 Kensington Greens Dr.	Painting Project	Disabled	
5/31/2020	37/38	All	All	Radison 1 and 2	All	Stuck Valve (After Hours Call)	Repaired	6/1/2020
5/29/2020	46/47	All	All	Tremont 1 and 2	All	Mainline Break	Repaired	6/1/2020
5/28/2020	All	All	All	All	All	Rain Delay	Resumed	5/31/2020
5/27/2020	39/40	34	Rotors	Oxford 1	1001-1009 Otter Mill Way	Low Flow Alarm Being watered manually	Repaired	5/28/2020
5/26/2020	42/43	31	Sprays	Southampton 2	1117-1127 New Windsor Loop	Low Flow Alarm Being watered manually	Repaired	5/28/2020
5/25/2020	All	All	All	All	All	Rain Delay	Resumed	5/26/2020
5/25/2020	53/54	All	All	Worthington / Yorkshire	All	Emergency Report	Enabled	5/27/2020
5/25/2020	51/52	All	All	Villeroy	All	Emergency Report	Enabled	5/27/2020
5/23/2020	16	7	Mixed	Highgate 2	2014-2024 Heathfield Cir.	Repair is needed	Enabled	5/27/2020
5/23/2020	15	4	All	Idlewood	1451-1550 Ingram Dr and 1400- 1408 Idlewood Dr. and 1508-1526 Ingram Dr	Repair is needed	Enabled	5/28/2020
5/23/2020	15	6	All	Idlewood	1508-1526 Ingram Dr	Repair is needed	Enabled	5/28/2020
5/23/2020	55/56	40	Rotors	Portsmith	2030-2052 Sifield Greens Dr.	Repair is needed	Enabled	5/27/2020

DAILY IRRIGATION OUTAGE REPORT


System is
Running


System is
Not Running


Temporarily
Paused


Program
Changed

Outage Date	Controllor	Zone	Zone Type	Association /Area	Effected Addresses	Issue	Status	Service Restore Date
5/23/2020	55/56	49	All	Portsmouth	2024-2052 Sifield Greens Dr.	Repair is needed	Enabled	5/27/2020
5/23/2020	57/60	2	Rotors	Devonshire	1122-1138 Corinth Greens DR-	Repair is needed	Enabled	5/27/2020
5/23/2020	57/60	7	Sprays	Devonshire	1156-1162 Corinth Greens DR	Repair is needed	Enabled	5/27/2020
5/23/2020	57/60	16	Sprays	Devonshire	1122-1128 Corinth Greens DR	Repair is needed	Enabled	5/27/2020
5/23/2020	61/63	25,26	Sprays	Fairbourne	1313-1323 Fairway Greens Dr.	Repair is needed	Enabled	5/27/2020
5/23/2020	61/63	38	Sprays	Fairbourne	1318-1330 Fairway Greens Dr.	Repair is needed	Enabled	5/27/2020
5/23/2020	61/63	48	Rotors	Edinburgh	1927-1943 Acadia Greens Dr.	Repair is needed	Enabled	5/27/2020
5/23/2020	61/63	65	Sprays	Edinburgh	1922-1928 Acadia Greens Dr.	Repair is needed	Enabled	5/27/2020
5/20/2020	67	All	All	Grantham	All	Control Point Alarm	Repaired	5/26/2020
5/20/2020	73	All	All	Oakley Greens	All	Pump Issue	Repaired	5/21/2020
5/19/2020	27	All	All	Manchester 4	All	Pump Issue	Repaired	5/21/2020
5/18/2020	All	All	All	All	All	Rain Delay	Resumed	5/19/2020
5/17/2020	48/50	85	Rotors	Acadia 1	2122-2144 Acadia Grenns Dr	Short Circuit	Repaired	5/21/2020
5/16/2020	8	17	Mixed	Gloucester M	2302-2348 Glenmore Circle	Short Circuit	Repaired	5/21/2020

DAILY IRRIGATION OUTAGE REPORT


System is
Running


System is
Not Running


Temporarily
Paused


Program
Changed

Outage Date	Controllor	Zone	Zone Type	Association /Area	Effected Addresses	Issue	Status	Service Restore Date
5/16/2020	35	All	Sprays	Nantucket 4	All	Emergency Report	Resumed	5/17/2020
5/15/2020	71/72	All	All	Lyndhurst / Maplewood	All	Mainline Break	Repaired	5/18/2020
5/14/2020	2	All	All	Bedford F	All	Painting Project	Enabled	5/26/2020
5/14/2020	48/50	All	All	Brookfield	All	Break	Repaired	5/15/2020
5/14/2020	26	All	All	Manchester 4	All	Mainline Break	Repaired	5/18/2020
5/13/2020	All	All	All	Section 1	All	Mainline Break	Repaired	5/14/2020
5/12/2020	57/60	All	All	Acadia 2	All	Pump Issue	Repaired	5/13/2020
5/11/2020	74	22	Drip	Richmond	2526-2520 Sapphire Greens	Short Circuit	Repaired	5/12/2020
5/10/2020	37/38	6	Rotors	Radison 2	1110-1130 Radison Ave.	LOW FLOW Alarm Being watered manually	Repaired	5/15/2020
5/9/2020	57/60	50	Sprays	Acadia 2	2110-2124 Acadia Greens Dr.	Break	Enabled	5/27/2020
5/9/2020	71/72	All	All	Maplewood / Lyndhurst	All	Mainline Break	Repaired	5/12/2020
5/9/2020	48/50	19	Sprays	Brookfield	2219-2225 Brookfield Greens Dr.	LOW FLOW Alarm Being watered manually	Repaired	5/15/2020
5/9/2020	51/52	All	All	Villeroy	All	Control Point Alarm	Repaired	5/11/2020
5/7/2020	67	All	All	Grantham	All	Control Point Alarm	Repaired	5/8/2020

DAILY IRRIGATION OUTAGE REPORT


System is
Running


System is
Not Running


Temporarily
Paused


Program
Changed

Outage Date	Controllor	Zone	Zone Type	Association /Area	Effected Addresses	Issue	Status	Service Restore Date
5/6/2020	75	36	Sprays	Nottingham	2236-2244 Nottingham Greens Dr	Short Circuit	Repaired	5/7/2020
5/6/2020	26	All	All	Manchester 3	All	Mainline Break	Repaired	5/8/2020
5/5/2020	48/50	24	Sprays	Brookfield	2259-2303 Brookfield Greens Dr	LOW FLOW Alarm Being watered manually	Repaired	5/8/2020
5/5/2020	41	All	All	Oxford 2	All	Control Point Alarm	Repaired	5/6/2020
5/5/2020	39/40	All	All	Oxford 1	All	Control Point Alarm	Repaired	5/6/2020
5/4/2020	26	All	All	Manchester 3	All	Mainline Break	Repaired	5/5/2020
5/3/2020	48/50	1	Rotors	Brookfield	2203-2217 Brookfield Greens DR	LOW FLOW Alarm Being watered manually	Repaired	5/8/2020
5/3/2020	51/52	All	All	Villeroy	All	Control Point Alarm	Repaired	5/4/2020
5/3/2020	55/56	13	Sprays	Corinth	1249-1259 Corinth Greens	Short Circuit	Repaired	5/5/2020
01/18/19	67	30	Drip	Grantham	2025 -2029 Grantham Greens	damage caused by homeowner.	Disabled	